

Dane do obliczeń : McCormic NOC proj 2018/03/15

Źródła punktowe

Nr	X[m]	Y[m]	z[m]	Pma	Symbol
=====					
1	445.5	733.1	1.0	70.0	pompy
2	455.0	735.4	2.0	76.0	chiler3
3	456.0	740.0	2.0	78.0	chiler6
=====					

Źródła typu hala produkcyjna :

WSPÓŁRZĘDNE WIERZCHOŁKÓW :

Nr	X1[m]	Y1[m]	X2[m]	Y2[m]	X3[m]	Y3[m]	X4[m]	Y4[m]	h0[m]	h[m]
=====										
1	480.4	782.4	491.4	780.4	488.2	764.3	477.4	766.4	0.0	8.0
2	466.4	739.8	473.8	738.4	472.8	732.0	465.5	733.6	0.0	8.0
3	463.7	725.4	471.3	723.8	470.1	717.0	462.0	718.4	0.0	8.0
4	461.7	717.7	498.1	709.7	487.0	658.0	450.5	665.0	0.0	8.0
5	450.2	664.6	474.0	660.0	471.2	646.7	447.9	652.1	0.0	8.0
6	443.4	666.1	440.3	653.1	446.9	652.1	449.3	665.1	0.0	5.0
=====										

POZIOMY HAŁASU i IZOLACYJNOŚĆ PRZEGRÓD

Nr	źródła	A	63	125	250	500	1000	2000	4000	8000	wsp.odb.
=====											
1	sc.1 L wew	85.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	sc.2 L wew	85.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	sc.3 L wew	85.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	sc.4 L wew	85.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	dach L wew	80.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R d	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
=====											
Nr	źródła	A	63	125	250	500	1000	2000	4000	8000	wsp.odb.
=====											
2	sc.1 L wew	95.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	sc.2 L wew	95.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	sc.3 L wew	95.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	sc.4 L wew	95.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	dach L wew	90.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R d	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
=====											
Nr	źródła	A	63	125	250	500	1000	2000	4000	8000	wsp.odb.
=====											
3	sc.1 L wew	80.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	sc.2 L wew	80.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000

	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
sc.3	L wew	80.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
sc.4	L wew	80.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
dach	L wew	75.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R d	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	

Nr źródła		A	63	125	250	500	1000	2000	4000	8000	wsp.odb.
4	sc.1 L wew	80.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	sc.2 L wew	80.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	sc.3 L wew	80.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	sc.4 L wew	80.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
dach	L wew	75.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R d	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	

Nr źródła		A	63	125	250	500	1000	2000	4000	8000	wsp.odb.
5	sc.1 L wew	80.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	sc.2 L wew	80.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	sc.3 L wew	80.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	sc.4 L wew	80.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
dach	L wew	75.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R d	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	

Nr źródła		A	63	125	250	500	1000	2000	4000	8000	wsp.odb.
6	sc.1 L wew	85.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	sc.2 L wew	85.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	sc.3 L wew	85.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
	sc.4 L wew	85.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R sc	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	
dach	L wew	80.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.0000
	R d	25.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	

Ekrany akustyczne :

WSPÓŁRZĘDNE WIERZCHOŁKÓW :

Nr	X1[m]	Y1[m]	X2[m]	Y2[m]	X3[m]	Y3[m]	X4[m]	Y4[m]	h0[m]	h[m]
1	474.1	738.2	483.1	736.5	479.4	714.2	470.4	716.2	0.0	8.0
2	465.6	733.4	472.4	731.9	471.1	724.0	463.6	725.6	0.0	8.0

3	498.3	709.7	514.5	705.9	503.8	653.8	487.2	657.4	0.0	8.0
4	474.8	659.6	503.5	653.6	500.2	639.8	471.1	644.8	0.0	8.0
5	447.4	651.1	500.2	640.6	458.2	435.6	404.2	446.4	0.0	8.0
6	527.6	785.0	536.8	783.2	532.0	755.5	520.1	757.7	0.0	5.0
7	446.6	651.8	440.1	653.0	436.6	637.6	443.4	636.2	0.0	5.0

WSPÓŁ CZYNNIKI ODBICIA DLA ŚCIAN

Nr	ściana 1	ściana 2	ściana 3	ściana 4	dach
1	1.0000	1.0000	1.0000	1.0000	1.0000
2	1.0000	1.0000	1.0000	1.0000	1.0000
3	1.0000	1.0000	1.0000	1.0000	1.0000
4	1.0000	1.0000	1.0000	1.0000	1.0000
5	1.0000	1.0000	1.0000	1.0000	1.0000
6	1.0000	1.0000	1.0000	1.0000	1.0000
7	1.0000	1.0000	1.0000	1.0000	1.0000